

**ADDENDUM# 1**  
**AIR CONDITIONING FOR HISTORY AND COMPUTER ROOMS**  
**AT NW LIBRARY**  
**Bid # 6598F**

**August 3, 2017**

The attention of bidders submitting proposals for the above-referenced project is called to the following Addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or other change, are all to be included in and form a part of the proposed Contract Documents for the work. Bidders shall acknowledge this Addendum.

**DRAWINGS**

1. Drawing M2 – Mitsubishi City Multi VRF Outdoor Unit Schedule – Provide unit with low ambient control for cooling below 0deg F.

Thank you for your patience, time and consideration.

C: Mike Longo, Facilities Manager  
Lucian Dragulski, PE, LEED AP, Bemis Associates LLC Consulting Engineers



**TOWN OF WEST HARTFORD**  
50 SOUTH MAIN STREET  
WEST HARTFORD, CONNECTICUT 06107-2431  
(860) 561-7470 FAX: (860) 561-7507  
[www.westhartford.org](http://www.westhartford.org)

*An Equal Opportunity/Affirmative Action Employer*